Initial Assessment for Sterile Processing & ST108 Compliance

This form is designed to help hospital water management teams assess the current state of their sterile processing unit per ANSI/AAMI ST108:2023. Your responses will be collected into a spreadsheet and sent to the email address you provide below.

RECOMMENDATION_Use the answers as a baseline to determine your next steps. Place initial focus on any acquiring the data questions you don't have answers for right now - filling in those gaps first will allow you to more effectively plan a phased implementation of solutions.

,	solutions.
* In	dicates required question
1.	Email *
Ste	erile Processing Department (SPD) Overview
2.	Do you have a distribution loop or direct feed system for your SPD water? *
	Check all that apply.
	Distribution Loop
	Direct Feed
	Not Sure
3.	Have all water entry points, treatment systems, and distribution paths been mapped?
	Check all that apply.
	Yes
	□ No
	Other:

4.	What water-quality challenges does the facility currently face? *	
	Check all that apply.	
	Scale (hardness)	
	Dissolved Salts	
	Sediment	
	Organic pollutants	
	Bacteria	
	Endotoxins	
	lonic Molecules (chlorine, iron, copper, etc)	
	Hq	
	Alkalinity	
	TOC	
	Color and Turbidity	
	Other:	
5.	Are devices pre-cleaned at the point-of-use before transport to SPD? (EX: operating room) Check all that apply. Yes No	*
6.	If yes, is water quality at point-of-use controlled or validated? Check all that apply.	
	Yes	
	□ No	

Water Treatment Evaluation [within SPD]

7.	In the sterile processing department, which water treatment systems are in place? *
	Check all that apply.
	Chemical treatment Green Sand Depth Filter Sediment Filters Softeners Carbon Filtration Carbon Adsorption Tanks pH Adjustment Bisulfite Injection Distillation Reverse Osmosis (RO) Systems Deionizer (DI) Systems / Exchange Resin UV Light Ultrafilters Ozone Steam Other:
8.	If a Reverse Osmosis (RO) system is in place, is free chlorine / chloramine pretreatment verified and monitored upstream? (If yes, document date of last test and method) Check all that apply. Yes No Other:

9.	What point-of-use equipment is in place within sterile processing? *
	Check all that apply.
	Initial Rinse Sinks
	Washers/Decontaminators
	Automated Endoscope Reprocessors (AERs)
	Sterilizers
	Storage Tanks
	Final Rinse Sinks
	Other:
10.	Which points-of-use currently use Utility Water? *
	Check all that apply.
	Initial Rinse Sinks
	Washers/Decontaminators
	Automated Endoscope Reprocessors (AERs)
	Sterilizers
	Storage Tanks
	Final Rinse Sinks
	Other:
11.	Which points-of-use currently use Critical Water? *
	Check all that apply.
	Initial Rinse Sinks
	Washers/Decontaminators
	Automated Endoscope Reprocessors (AERs)
	Sterilizers
	Storage Tanks
	Final Rinse Sinks
	We don't have Critical Water - everything uses Utility Water
	Other:

12.	Which points-of-use have commercial filtration? *	
	Check all that apply.	
	□ N/A	
	Initial Rinse Sinks	
	Washers/Decontaminators	
	Automated Endoscope Reprocessors (AERs)	
	Sterilizers	
	Storage Tanks	
	Final Rinse Sinks	
	Other:	
13.	Which points-of-use have microbiological filtration? *	
	Check all that apply.	
	□ N/A	
	Initial Rinse Sinks	
	Washers/Decontaminators	
	Automated Endoscope Reprocessors (AERs)	
	Sterilizers	
	Storage Tanks	
	Final Rinse Sinks	
	Other:	
14.	If microbiological filtration is in place, what is the current pore size and where is it	*
	placed? (ie, is it installed on fixtures or directly to water lines?) Enter N/A if	
	appropriate	
		_
		_
		_
		_

	Which points-of-use require, or may require, source water changes? (ie, utility vs * critical water)	
	Check all that apply.	
	N/A	
	Initial Rinse Sinks	
	Washers/Decontaminators Automated Endoscope Perrocessors (AEPs)	
	Automated Endoscope Reprocessors (AERs) Sterilizers	
	Storage Tanks	
	Final Rinse Sinks	
	Other:	
Maiı	ntenance Evaluation	
	iterialice Evaluation	
	iteriance Evaluation	
16		
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? *	
16.		
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? *	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply.	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A Initial Rinse Sinks	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A Initial Rinse Sinks Washers/Decontaminators	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A Initial Rinse Sinks Washers/Decontaminators Automated Endoscope Reprocessors (AERs)	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A Initial Rinse Sinks Washers/Decontaminators Automated Endoscope Reprocessors (AERs) Sterilizers	
16.	Which points-of-use are being maintained in accordance with manufacturer's IFU? * Maintenance includes disinfection if appropriate Check all that apply. N/A Initial Rinse Sinks Washers/Decontaminators Automated Endoscope Reprocessors (AERs) Sterilizers Storage Tanks	

17.	Which points-of-use are require disinfection? *
	Check all that apply.
	N/A Initial Rinse Sinks Washers/Decontaminators Automated Endoscope Reprocessors (AERs) Sterilizers Storage Tanks Final Rinse Sinks Other:
18.	Regarding disinfection throughout SPD, list each type of disinfectant used along * with amounts and frequency of use
19.	How frequently are sediment filters monitored for clogging? * Check all that apply. Daily Weekly Monthly Quarterly Other:
20.	Current status of carbon adsorption tank chlorine levels: (enter current chlorine * levels or N/A if not in use)

Current Water Quality Values

21.	Is the pH level within the specified range for each water type? (Utility 6.5 - 9.5, Critical 5.0 - 7.5, Steam 5.0 - 9.2)	*
	Check all that apply.	
	Yes No For Utility only For Critical only For Steam only	
22.	Enter the most recent pH level readings for Utility and Critical Water, and Steam *	
23.	Enter Total Alkalinity Levels (mg CaCO3/L) for Utility, Critical Water, and Steam: (ensure Utility <400 mg CaCO3/L, Critical <8 mg CaCO3/L, Steam <8 mg CaCO3/L)	*
24.	Enter current Bacteria level (CFU/mL) for both Utility and Critical Water: (ensure Utility <500 CFU/mL, Critical <10 CFU/mL)	*
25.	Enter Endotoxin level (EU/mL) for Critical Water: (ensure <10 EU/mL) *	

26.	Enter Total Organic Contaminants (TOC) level for Critical Water: (ensure ≤1.0 mg/L (ppm))	*
27.	Enter Color and Turbidity description for Utility, Critical Water, and Steam: (ensure colorless & clear w/out sediment for all)	*
28.	Enter Conductivity levels for Utility, Critical Water, and Steam: (measure with calibrated, temperature-compensated conductivity meter; specify the values in μ S/cm)	*
	NOTE: Conductivity equals total amount of electrically charged impurities (ions); see pg 19 in ST108)	
29.	Enter Water Hardness levels (CaCO3/L) for Utility, Critical Water, and Steam: (ensure Utility <400 mg CaCO3/L, Critical <8 mg CaCO3/L, Steam <8 mg CaCO3/L)	*
Doc	umentation	
30.	Is maintenance scheduled for all equipment in line with ANSI/AAMI ST108? *	
	Check all that apply.	
	Yes	
	□ No	
	Other:	

31.	When was the last disinfection of the distribution loop?	
	Example: January 7, 2019	
32.	Are logs up-to-date for each maintenance and monitoring activity? *	
	Check all that apply.	
	Yes No	
	Other:	
33.	Are all test results and corrective actions documented in accordance with hospital protocol?	*
	Check all that apply.	
	Yes No	
	Other:	
34.	Is there a designated individual or team for overseeing water quality	*
	management?	
	Check all that apply.	
	Facilities Engineering	
	Infection Control	
	Water Treatment Specialist	
	Biomeds	
	Other:	

Risk Analysis

35.	Has a risk assessment been conducted for microbial risks in the sterile processing unit?	*
	Check all that apply.	
	Other:	
36.	Having completed the previous questions, have you identified the potential for adverse effect(s) to:	*
	Check all that apply.	
	Medical device(s) Process	
	Patient Personnel	
37.	Identify any corrective actions needed based on recent water-quality assessments: (describe any observed issues, such as scaling, biofilm buildup, or other compliance concerns)	*
		_
		_

fection, equipment damage):
entify all existing sample ports and whether they are dead legs. (if there are ead legs, are they being flushed routinely? are the sample ports in the opropriate locations? are additional ports needed?)
you have a documented plan in place for out-of-range results and nergencies?
nergencies:

This content is neither created nor endorsed by Google.